

Bridgeport Fittings Inc.

705 Lordship Blvd. Stratford, CT 06615


Phone: 203-377-5944 Fax: 203-381-3488

Zinc - EMT/Rigid Transition - Raintight

Images



Download Photo Image



Download Dimensional Image

Dimension A in Inches: 1.68 Dimension B in Inches: 1.33

Application

Used to make transition from Rigid Metallic Conduit & amp; amp; IMC to EMT in wet and dry locations.

Product Information

Material: High Strength Zinc Alloy

Ball Burnished Finish:

Certifications & Codes:

Federal

Specification A-A-50553A

Number:

NEMA

FB-1 Standard:

UL File

ETL Bridgeport Fittings 291-RT Number:

Listed ETL Conforms to UL STD

UL Standard: 514B Certified to CAN/CSA STD.

C22.2 No. 18.3

UNSPSC: 39131707

Patent

7,390,027

Number:

Catalog ID: 291-RT

UPC Number: 78174794261

Description: Combination coupling for transitioning between 3/4" Rigid or IMC raceways to 3/4" EMT in wet or dry locations. Listed for use in wet locations. Raintight

Application: Used to make transition from Rigid Metallic Conduit & amp; amp; IMC to EMT in wet and dry

locations.

Trade Size: 3/4"

Std Pkg Qty: 100

Unit Qty: 25