



# HOSPITAL GRADE SURGE PROTECTIVE DUPLEX RECEPTACLE, IVORY

8200ISP | Pass & Seymour

#### **FEATURES & BENEFITS**

Hospital Grade Surge Protective Duplex Receptacle offers increased transient protection, reliability and protection notification (Audible Alarm with LED Indicator). Back & Side Wire, 15amp 125volt, Ivory.



- Solid-state LED monitor has 25-year minimum life expectancy. A high visibility, wide-angle lens indicates protection is in place.
- LED Indication: Steady green = protected, Flashing re = not protected, OFF = no power to unit
- Audible alarm alert of MOV damage. Alarm able to be turned On/Off.
- Wrap-around steel strap for structural integrity. Auto-ground is standard, for easier installation.
- Impact-resistant thermoplastic exterior resists impacts and scrapes.
- **Triple-wipe, copper-alloy contacts** for superior, more dependable connection.
- External screw-pressure-plate back and side wire terminals including ground with external back wire clamps (exclusive) accept #14 #10 AWG copper or copper-clad, solid or stranded conductors. External pressure plate feature allows two conductors to be terminated by a single screw.
- Thermal protection in 3 modes. 3 17mm dual pack MOVs absorb up to 340 Joules of excess energy in each leg (L-N, L-G, N-G) with 24,000 amp current handling capability for full, equal and symmetrical protection. Protection response time in less than one nanosecond.
- For covering patents, see www.legrand.us/patents.

## **SPECIFICATIONS**

### **GENERAL INFO**

Color: Ivory Type: Duplex

Special Features: Isolated Ground, Audible Alarm with LED Monitor

#### LISTING AGENCIES/THIRD PARTY CERTIFICATIONS

CSA Listing Info: No

CUL Listing No: No

cULus: Yes cURus: No

Federal Spec: Yes UL Listing No: No UN SPSC: 39121406

UR: No

#### **DIMENSIONS**

Depth (US): 1.225" (Behind Strap)

Height (US): 3.82" Width (US): 1.75"

# TECHNICAL INFORMATION

Amps: 15A Volts: 125V Volts (AC): 125 Grade Type: Hospital

# **BUY AMERICAN ACT COMPLIANCE**

Country Of Origin: CHINA Buy American Act Status: No